

Letter No. 802 Dated: 31/07/2023
 Government of Bihar

DISTRICT LEVEL WATER TESTING LABORATORY UNDER PUBLIC HEALTH DIVISION ARARIA.
CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES

District Name: -- ARARIA

Month - JULY - 2023

SL. No.	Location of Source	Parameters Examined																Remarks
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Bacteria		
1	Scottish Public School, Rajokhar, Araria	7.2	0.5	196	128	92	16.0	12.63	40	72	0.31	BDL	5	-	-	-Ve	Acceptable	
		Desirable Limit* 6.5-8.5		1.0	-	500	200	75	30	250	200	1.0	45	200	1.0	0.01	-	
		Permissible Limit* in absence of alternate source		NR	5.0	-	2000	600	200	100	1000	600	NR	400	1.5	NR	**	

Note - (i) Drinking Water Specification Second Revision -IS: 10500: 2012, (ii) BDL means Below Detection Limit, (iii) NR means no relaxation and (iv)** Shall not be detectable in any 100ml sample

- : - All Test Done By Lab Assistant / Chemist


 Lab Assistant
 31/07/2023


 Chemist (Lab Incharge)
 P.H.Division, Araria.


 Assistant Engineer
 P.H. Sub Division, Araria West.


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 789

Date : 24/07/2023

It is certified that an inspection team headed by **Arvind Kumar, J.E. (P.H.E.D)** from P.H. Sub- Division, Araria (West) inspected the **SCOTTISH PUBLIC SCHOOL, RAJOKHAR, ARARIA** on Dated 24/07/2023 and found that the **SCOTTISH PUBLIC SCHOOL, RAJOKHAR, ARARIA** has Safe Drinking Water Facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of **One year**


24/07/23
J.E

P.H.Subdivision,
Araria West

Signature With Seal : 

Name

:-Amar Kumar-

Designation

:-Assistant Engineer--

P.H.Sub Division Araria West.

To,

Principal,
Scottish Public School,
Rajokhar, Araria
Araria - 854312

(Name & Address of The Institution)